

Legionnaires Disease Update

Please find below the latest update regarding Legionella within the Trenton P&DC Plant and VMF. This update is directly from the company conducting the testing.

As requested, below are the results from the third round of legionella sampling at the Trenton NJ P&DC. 2 of the 4 samples collected were still found to be positive for legionella which included the following locations:

- Processing & Distribution Center Custodial Storage Cold Water Valve (Cold Water)

This sample was barely detectable and there is a very good chance that one more chlorine treatment will remove detectable legionella. Another option here is to also replace the fixture which would help remove the legionella.

- Vehicle Maintenance Garage Bay 5 Hose (Hot & Cold)

For this sample of a higher detection, in addition to flushing with chlorine, I recommend replacing the hose which will also help remove the legionella.